



No. 0307/ **8952**

To A.T. Con Insulation Co., Ltd.

The Department of Science Service presents the test report for the sample named
“Expanded polystyrene Foam (EPS) 2.5LB/cuft” Laboratory No. L68/03757.7 as the total of 1
sample with reference to the request No. L68/03757 dated 6 August 2025.

Enclosed herewith the following result avails for your acknowledgement.

Department of Science Service



Physical Reference Laboratory Center

Tel. 0 2201 7130

Fax 0 2201 7127

E-mail : physics@dss.go.th



TEST REPORT

Sample's name

Expanded polystyrene Foam (EPS)

2.5LB/cuft

(A.T. Con)

Mark / Brand

Laboratory No.

L68/03757.7

Test Result

Modulus of Elasticity, kPa

80,600

Customer's name

A.T. Con Insulation Co., Ltd.

Customer's address

636/7 Moo 3, Puttaraksa Road, Phraekasa, Mueang, Samutprakan 10280

Sample's description

Cubic foam

Test date

13 August 2025

Test method

ASTM D6817-02

Approved by

(Mr. Somchai Sirilertpitak)

Scientist, Senior Professional Level

Reported by

(Mr. Aekapon Pokhum)

Mechanic, Experienced Level